

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251165

Address: 628 SE BRADFREE ST, LEES SUMMIT, MO 64063630 SE BRADFREE ST, LEES SUMMIT, MO 64063632
SE BRADFREE ST, LEES SUMMIT, MO 64063626 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Dustin Agcopra	Failed	Wednesday, February 11, 2026

Corrective Action Required:

1	Miscellaneous Correction	2-11-26 Dustin A, Public sidewalk is not installed in rear of lot. Hydrant valve has been hit and laid over. Cannot get a hydrant key on it . Will need to be cut to final grade as well
---	-----------------------------	--

Comments: