

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254101
Address: 2233 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Wednesday, February 11, 2026

Informational:
1 Misc Portal frames front and rear ok to cover

Corrective Action Required:
2 Misc 2233 SW Heartland Ct

- Block off electrical boxes in return air chase master bedroom/bath wall
- Fire blocking above both bedroom window transitions from wall to soffit
- Add plate to protect main electrical service wire at bottom plate in front bedroom

Corrective Action Required:
3 Misc

Comments: