

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250097
Address: 2221 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Wednesday, February 11, 2026

Corrective Action Required:

1	Misc	2/11/26 Tyler S. Silt fence down. Needs silt fence around property and around field storm inlet. Spoke with Bill and said he would call Gordon to get this corrected. Also dirt and debris in road and tracked up the street. Road needs to be cleaned up. Also need to remind people to use construction entrances. Fail.
---	------	--

Corrective Action Required:

2	Misc
---	------

Comments: