

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20252931  
Address: 1218 SE WINDBREAK DR, LEES SUMMIT, MO 64081  
1216 SE WINDBREAK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Thursday, February 12, 2026

Corrective Action Required:  
1 Misc unit 1218 - Exterior outlet at AC unit must be GFCI protected

**Comments:**