

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Thursday, February 12, 2026

Corrective Action Required:
1 THIRD FLOOR -Screw pattern and fire tape behind tubs ok
 -RC approved throughout
 -Screw pattern at units approved

Corrective Action Required:
2 SECOND FLOOR -Screw pattern and fire tape behind tubs ok
 RC at units only approved

Corrective Action Required:
3 FIRST FLOOR -Screw pattern and fire tape behind tubs ok

 RC approved except as noted:
 -Corridor not ready, 102 incomplete at SE cables, Clubhouse not inspected

Comments: