

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235206  
Address: 2971 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Failed	Friday, February 13, 2026

Corrective Action Required:  
1 Misc Garage PHF portal walls framing-OK to cover  
  
\*\*install blockings under window jack and kings studs

Corrective Action Required:  
2 LOWER LEVEL OK:  
-Pre-rock for corridor ceiling  
  
\*\*Pre-rock at showers and tubs corrections:  
007:  
-Strap over-bored top plate per plan

Corrective Action Required:  
3 FIRST FLOOR OK:  
-Pre-rock for corridor ceiling  
-Pre-rock at showers and tubs

Corrective Action Required:  
4 SECOND FLOOR OK:  
-Pre-rock for corridor ceiling  
-Pre-rock at showers and tubs

Corrective Action Required:  
5 THIRD FLOOR OK:  
-Pre-rock for walls at showers and tubs

