

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235203
Address: 2991 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	Dustin Agcopra	Partial	Friday, February 13, 2026

Informational:
1 Misc 2-13-26 Dustin A, Gravel is installed per details. There are some spots that need to be set back more and spots were silt is getting through. Pond will need to be dug out . French drain line needs to be extended past the wall

Comments: