

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235203
Address: 2991 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Retention Basin	Dustin Agcopra	Partial	Tuesday, February 17, 2026

Corrective Action Required:

1	Misc	2-13-26 Dustin A, . Selby working on retention pond behind apartments. Fabric and gravel is installed per detail. There are some sections around the pond where there are to big of gaps in the rocks, and some of the rocks needed to be set back a bit for the 6 inch lip.
---	------	--

Comments: