

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250026
Address: 643 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Tuesday, February 17, 2026

Informational:

1 Misc

Portal frame inspection only

- Garage
- Front porch window,
- front porch ceiling trusses and beams,
- nail pattern on osb on front of house.
- truss hold downs in second floor HVAC closet (front side of stairwell- small closet)
- Permission to drywall for hvac installation.

Approved

Corrective Action Required:

2 Miscellaneous Correction

- master bedroom north west corner
Corner studs need nailed 2 nails every 12"

Comments: