

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251179  
Address: 15 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, February 17, 2026

Corrective Action Required:		
1 FIRST FLOOR	-Pre rock behind tubs and showers ok	
Corrective Action Required:		
2 SECOND FLOOR	-Pre rock behind tubs and showers ok	
Corrective Action Required:		
3 THIRD FLOOR	Approved	

**Comments:**