

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20243308
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Dustin Agcopra	Partial	Wednesday, February 18, 2026

Informational:

1 Misc

2-17-26 NS Site visited for bacteriological sampling associated with new water main installation. Two bacteriological samples were collected today at approximately 11AM to and transported to Blue Vally Labs at 2pm today. Water main pending acceptable bacteriological results prior to approval for service.
2-18-26 NS Back-T test came back, and both samples passed on the first round of test. results will be uploaded to permit.

Comments: