

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253573
Address: 1021 SW JEFFERSON XING, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Shawn Hoffman	Partial	Thursday, February 19, 2026

Corrective Action Required:

1 Misc

APPROVED TO POUR

- TUNNEL PIT FLOOR OK
- FOOTING FOR ALL OF BUILDING
- UFER COPPER TO FOOTING GRID AT NORTH WALL WEST END
- CONDUIT IN FOOTING
- TRASH ENCLOSURE FOOTING

Comments: