

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254263
Address: 1122 SE RANCLAND ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Thursday, February 19, 2026

Corrective Action Required:

1	Miscellaneous Correction	- Outlet cover missing in upstairs hallway - Non gfci outlet in basement not labeled - Missing security screws at front door
---	--------------------------	--

Comments: