

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251179
Address: 15 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Monday, February 23, 2026

Corrective Action Required:

1	FIRST FLOOR	-Pre rock behind tubs and showers ok 2/23/26-NOT READY. Complete electrical, complete sprinkler, protect DWV
---	-------------	---

Corrective Action Required:

2	SECOND FLOOR	Throughout: -Install traps for 3rd floor tubs
---	--------------	--

Corrective Action Required:

3	THIRD FLOOR	Approved
---	-------------	----------

Comments: