

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Nick Scott	Temporary C of O	Monday, February 23, 2026

Corrective Action Required:

1 Misc

Punch list 12-17-25 NS

1. Vegetation
2. clean storm boxes throughout site for trash.
3. asphalt is chipped out into the driveway and needs to be repaired.
4. cracked panels need to be replaced. Marked with Pink spray paint.
5. Clean all trash and construction materials in parking lot.

2-23-26 NS Site visited and after reviewing punch list and observing what is on site.

1. all vegetation has to be established.
2. all construction materials need to be removed from development area
3. Parking lot clean up much and gravel.

Once these are complete, we will fully pass the Occupancy Inspection.

Comments: