

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20250043
Address: 664 SE WOOD LN, LEES SUMMIT, MO 64063

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Monday, February 23, 2026

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	2-20-26 Dustin A, Silt fence is knocked down by contractors. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. (2-23-26)
		2-23-26 Dustin A, No steps have been made to correct this. STOP WORK issued, Must call in a erosion inspection once either silt fence is corrected and or a proper construction entrance is installed and curb lines are cleaned ,

Comments: