

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253425  
Address: 2612 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Wes Bears	Failed	Monday, February 23, 2026

**Corrective Action Required:**

1	Miscellaneous Correction	- electric outlet on back patio is not WR - secondary lock on patio door is not functioning correctly
---	--------------------------	----------------------------------------------------------------------------------------------------------

**Comments:**