

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241886
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Monday, February 23, 2026

Corrective Action Required:

1	Misc	OK to cover: -Above ceiling in units
---	------	---

Corrective Action Required:

2	FIRST FLOOR	2/23/26 Inspection for above ceiling at entryways Ann bathrooms ***Not ready, correct the following before rescheduling -Seal all penetrations above framing and in dead spaces
---	-------------	---

Comments: