

MICHAEL MOORES, RA
(816) 516-4861

Development Services
CITY OF LEE'S SUMMIT, MISSOURI
220 SE Green Street
Lee's Summit, MO 64063

Re: PGM
636 NE Maguire Blvd
Lee's Summit, MO 64064
Permit No.: PRCOM20260565

February 24, 2026

Dear Plans Examiner:

We have received your plan review comments and have itemized our responses to correspond with each comment.

Licensed Contractors:

1. R2 Plumbing license resolved.

Building Plan Review:

1. The one-time impact fee with additional application is acknowledged.
2. Please see the revised sheet A-001 that shows the project summary updated to reflect the change in items stored.

Fire Plan Review:

1. Please see the revised sheet A-001 that shows the project summary updated to reflect the change in items stored. The tenant has indicated that the caskets will not be stored on racks, but they will be stored on the floor around the perimeter of the warehouse space to keep the exit paths clear and to not obstruct fire department access or interfere with fire protection systems.
2. Shop drawings will be submitted for review and approval as a deferred submittal by the Fire Alarm System contractor.
3. Shop drawings will be submitted for review and approval as a deferred submittal by the Fire Suppression System contractor.
4. No known hazardous chemicals are anticipated to be stored on site.

Please call if you have any questions.

Sincerely,

MICHAEL MOORES, RA