



Action Required: Provide deferred submittal for fire protection system.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved with Conditions**

1. A one-time impact fee in the form of an excise tax must be collected before occupancy can be granted. Please be advised that additional application, review, and inspection fees do apply and additional information pertaining to this will be provided during that stage of your approval process.

Action required: Comment is informational. The fee will be \$18,001.50  
2/19/2026 - Acknowledged in letter.

4. ICC A117.1 Section 904.3 Sales and service counters and windows. Sales and service counters and windows shall comply with Section 904.3.1 and either 904.3.2 or 904.3.3. Where counters are provided, the accessible portion of the countertop shall extend the same depth as the public portion of the sales and service countertop provided for standing customers. (see code for exception) 904.3.1 Vertical barriers. At service windows or service counters, any vertical barrier between service personnel and customers shall be at a height of 43 inches maximum above the floor. (see code for exception regarding security glazing) 904.3.2 Parallel Approach. A portion of the public use side of the counter surface 36 inches minimum in length and 26 inches minimum and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a parallel approach adjacent to the accessible counter shall be provided. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12 inches minimum. (see code for exception) 904.3.3 Forward Approach. A portion of the public use side of the counter surface 30 inches minimum in length and 36 inches maximum in height above the floor shall be provided. A clear floor space positioned for a forward approach to the accessible counter shall be provided. Knee and toe clearance complying with Section 306 shall be provided under the accessible counter. The space between the accessible counter surface and any projecting objects above the accessible counter shall be 12" minimum.

Action required: Comment is informational. If a point of sales counter is provide it must be accessible.  
2/19/2026 - Acknowledged in letter.

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Approved**