

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250449
Address: 1231 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Tuesday, February 24, 2026

Corrective Action Required:

1	Misc	-conduit and ground rods for (8) light poles from building at west -conduit and ground rods for (6) light poles at north lot and EV charger -4" Conduit for fiber from new tower location to existing building at south side -From east side to island boxes and to (21) light poles at east lot -From islands to pull box in east lot
---	------	--

Comments: