

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253777
Address: 2037 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Passed	Wednesday, February 25, 2026

Corrective Action Required:

1	Misc	2/25/26 Tyler S. DW i is no compacted. Needs to be compacted before able to pass inspection. Fail 2/25/26 Tyler S. DW is formed and compacted with 4" of clean rock. Approve to pour.
---	------	--

Comments: