

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251178
Address: 11 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, February 25, 2026

Corrective Action Required:
1 THIRD FLOOR Pre rock behind tubs ok to cover
Corrective Action Required:
2 SECOND FLOOR Pre rock behind tubs ok to cover
Corrective Action Required:
3 FIRST FLOOR Pre rock behind tubs ok to cover

Comments: