

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251957
Address: 240 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, February 25, 2026

Informational:

1 Misc

The following areas inspected and marked on plans in job trailer

-conduit for 3 E most light poles

-conduit for light poles and monument sign NW side of building

-conduits from NE corner of building to 3 light poles along south side of parking lot, to SW light pole near traffic light, and to nearby monument sign; conduits

to trash compactor and light pole adjacent of fire hydrant near trash enclosure

-bollard light conduit from east to south side of building, approx 1/2 side

-secondary conduits to service location

Comments: