

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250070
Address: 624 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Thursday, February 26, 2026

Corrective Action Required:

1	Miscellaneous Correction	-Door bell cover missing -door at mechanic room will not close properly -mechanic room wall needs for black at power line and a/c line - outlet cover missing in master bathroom -attic entry cover not in place -gfcı outlet at a/c unit not working outside -no sod -no splash blocks
---	--------------------------	--

Comments: