

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250006
Address: 632 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------------|
| All Rough Inspection - Residential | Wes Bears | Failed | Thursday, February 26, 2026 |

Informational:
1 Misc PFH at garage and front porch ok
Front porch trusses ok
Nailing on front of house ok to cover

Corrective Action Required:
2 Misc -tighten all anchor bolts
-nails missing it truss bracket at half bath
-fire block around duct work in mechanical closet
-protect dryer duct

Comments: