

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250014
Address: 636 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Thursday, February 26, 2026

Informational:

1	Misc	PFH at garage and front porch ok to cover - mechanical room ok to Sheetrock - front porch ceiling ok to cover
---	------	---

Corrective Action Required:

2	Misc	Inspection denied no fire blocking done throughout. Complete fire blocking before calling for inspection
---	------	--

Corrective Action Required:

3	Miscellaneous Correction	-fire block around sewer lines in garage -fix hole on siding north wall in garage -fire block around duct in mechanical room -fire block around dryer duct through floor -nail corner studs to code
---	--------------------------	---

Comments: