



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20116155, Building Permit - Residential
Address: 1721 NE WOODLAND SHORES CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Not Ready	Tuesday, May 15, 2012

Corrective Action Required
1 MISC

NOT READY FOR INSPECTION

*HAVE THE APPROVED PLAN ON SITE FOR INSPECTION

*I SEE TOO MANY FRAMING DEFICIENCIES. HAVE THE
STRUCTURAL ENGINEER GO THROUGH THE HOUSE TO
CORRECT THINGS THAT NEED TO BE CORRECTED.

Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Tuesday, May 15, 2012
--	--------------	--------	-----------------------

Corrective Action Required
1 MISC

PROVIDE LISTING OF THE GROUNDING CLAMP TO REBAR.

Gas Service Inspection - Residential	Khanh Nguyen	Passed	Tuesday, May 15, 2012
---	--------------	--------	-----------------------

Comments: