

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20255132  
Address: 2112 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Tyler Schreck	Failed	Monday, March 02, 2026

**Corrective Action Required:**

1	Misc	3/2/26 Tyler S. No erosion control in place. Silt fence is all down. mud is in the road and needs to be cleaned up asap. Construction entrance needs to be established enough to where we are not tracking into the roadway. Fail.
---	------	--

**Comments:**