

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at [DEVSERVICES.CITYOFLS.NET](http://DEVSERVICES.CITYOFLS.NET)**

## Inspection Summary

Permit #: PRCOM20251957  
Address: 240 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	Patrick Schonfeldt	Passed	Monday, March 02, 2026

Informational:  
1 Misc 3/2/26 PS Observed contractor (Bair) perform hydrostatic test at fire line from vault to interior riser. Testing passed, held 200 psi for 2 hours.

**Comments:**