



March 2, 2026

City of Lee's Summit, Missouri
Development Services
4800 E 63rd Street
Kansas City, MO 64130

**RE: Hook Farms Third Plat
Application Number PRSUBD20260019**

We are responding to your water comments dated February 27, 2026, and are submitting with this letter revised plans, and other required documents. Please find the original comments below; our responses are below in bold italics.

If you have any questions or need additional information, please do not hesitate to contact us.

Thanks,

A handwritten signature in blue ink that reads "Stephen Saylor".

Stephen Saylor, P.E.

Engineering Review – Water by Gene Williams

1. Add a valve northwest of the valve at Sta. 24+38.56 on sheet 307.
An 8" gate valve has been placed at the lot line of 231/232. The general layout and quantities have also been updated.