

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253777  
Address: 2037 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                       | Inspector:    | Outcome: | Date:                      |
|---|---------------|----------|----------------------------|
| <b>Erosion Control Inspection<br/>Residential</b> | Tyler Schreck | Failed   | Tuesday, March 03,<br>2026 |

**Corrective Action Required:**

|   |      |   |
|---|------|---|
| 1 | Misc | 3/3/26 Tyler S. Erosion control failed. Silt fence is down and needs put back up. |
|---|------|---|

**Comments:**