

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20260507
Address: 3821 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Tuesday, March 03, 2026

Corrective Action Required:

1	Miscellaneous Correction	Fur downs for ducts and steel beams need to be fire blocked with approved materials. 2024 IRC 302.11.1 has that list.
---	--------------------------	--

Comments: