

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251423

Address: 616 SE LINDBERG LN, LEES SUMMIT, MO 64063618 SE LINDBERG LN, LEES SUMMIT, MO 64063620  
SE LINDBERG LN, LEES SUMMIT, MO 64063614 SE LINDBERG LN, LEES SUMMIT, MO  
64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Drew Fischer	Failed	Thursday, March 05, 2026

Corrective Action Required:

1	Misc	at garage PFH walls; tighten down hold-down; hold-down bolt must go through full depth of nut -Fill in space below master shower wall and fasten wall to floor
	616:	-at garage PFH walls; tighten down hold-down; hold-down bolt must go through full depth of nut -Fill in space below master shower wall and fasten wall to floor
	618-	at garage PFH walls; tighten down hold-down; hold-down bolt must go through full depth of nu
	620:	garage PFH walls; tighten down hold-down; hold-down bolt must go through full depth of nut -Submit engineer fix for damaged trusses above entry

**Comments:**