

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251178
Address: 11 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|---------------|----------|--------------------------|
| Rated Assembly Inspection | Shawn Hoffman | Partial | Thursday, March 05, 2026 |

Corrective Action Required:
1 Misc - 302,303,306 Block out top plate of chase at separation wall.

Inspected 3rd Floor Only all other units ready to tape.

Comments: