



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110083, Building Permit - Commercial
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Residential	John Borns	Partial	Wednesday, May 16, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY THREE 4" PVC SECONDARY ELECTRICAL SERVICE CONDUITS FROM TRANSFORMER LOCATION TO BUILDING ENTRY; TWO 2" TELEPHONE SERVICE CONDUITS FROM MANHOLE TO BUILDING ENTRY

Partial Correction
2 MISC

BURIED CONDUIT FOR SITE LIGHTING AND DATACOM COVERED WITHOUT INSPECTION EXPOSED AT <= 15' INTERVALS TO VERIFY SIZE AND DEPTH. NO ISSUES FOUND.

Comments: