



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, May 17, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED ASSEMBLIES: FRAMING AND SHAFT LINER AT INTERIM CLOSURES AT ELEVATOR DOORS @ 1ST FLOOR;

In-wall Inspection	John Borns	Partial	Thursday, May 17, 2012
---------------------------	------------	---------	------------------------

Partial Correction
1 MISC

OK TO TOP-OUT GWB WALL DOWN TO ~ 10' A.F.F. AT FOLLOWING WALL PLANES: (CC) FROM (0.3) TO (3.7); (A.5) FROM (6.0) TO (4.9); (CC.4) FROM (0.5) TO (3.4); 149 OR-4 N WALL; 141 OR-5 N WALL;

Partial Correction
2 MISC

OK TO COVER WHEN READY GWB WALLS FULL HEIGHT @ FOLLOWING LOCATIONS: AHU RM 147 NE CORNER FOR MOUNTING OF DP-E1-28-HA; 126 & 127 FOR EQUIPMENT INSTALL; TEMPORARY EGRESS CORRIDOR @ 117; INFILL BELOW WINDOWS ALONG (DD) FROM (3.8) TO (5.1);

Comments: