

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRESRES20253206

Address: 231 NW ORCHARD CT, LEES SUMMIT, MO 64063229 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Drew Fischer	Passed	Thursday, March 05, 2026

Informational:

1 Misc

Above ceiling attic screw pattern ok, behind furnace ductwork screw pattern good and tape /mud complete, ok to set rest of ductwork

Informational:

2 Misc

Party wall screw pattern good in both units 229,231

Comments: