CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253973
Address: 2038 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Tyler Schreck	Failed	Monday, March 09, 2026

Corrective Action Required:

1	Misc	3/9/26 Tyler S. After pour inspection. SW slope are good. However, there needs to be an expansion joint every 100 ft. Also, the white cure is not uniform and looks like maybe had issues with the application process. Looks speckled and in some places looks just slopped on. Fail.

Comments: