

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20243308
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Tyler Schreck	Passed	Monday, March 09, 2026

Corrective Action Required:

1	Misc	3/9/26 Tyler S. Preformed hydrostatic test on C line. Held for 2 hrs. at 150 PSI. with no leak. Passed.
---	------	---

Comments: