

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253743  
Address: 2033 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Tyler Schreck	Failed	Tuesday, March 10, 2026

**Corrective Action Required:**

1	Miscellaneous Correction	12/19/25 Tyler S There is no erosion control in front of house along curb. Silt fence is also down along the east side of property. Failure to correct this can result in a 2 day stop work order. 3/3/26 Tyler S. Mud and rock has been tracked out into the road. Needs to be cleaned up ASAP. 3/4/26 Tyler S. More mud and rock has been tracked out into road and silt fence is still down. Road needs to be cleaned up asap and erosion control needs to be fixed and maintained. A two day stop work order will be issued if this matter is not corrected. Fail. 3/10/26 Tyler S. More rock has been tracked into the road on top of what was there already that still has not been cleaned up. All rock and mud MUST be cleaned up. And erosion control needs maintained, silt fence is down. You have 2 days to correct this issue and clean up the street or a STOP WORK order will be issued. More rain is coming so we need to be sure we are keeping things clean.
---	-----------------------------	---

**Comments:**