

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250025
Address: 635 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, March 10, 2026

Informational:

1 Misc

following areas inspected
-exterior nail pattern
-truss hold downs at front porch and 2nd floor mechanical

Corrective Action Required:

2 Misc

- support 3" DWV above garage
- Missing anchor bolt at sill plate exterior wall garage/ entry door
- Strap and fasteners needed at top plate exterior wall at line set
- Fire block top plate of double wall by refrigerator
- Nail off double truss in master bedroom

Comments: