

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20250106
Address: 1817 NE LASHBROOK CIR, LEES SUMMIT, MO 64086
Inspected On: Wednesday, March 11, 2026
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Ready for Temp CO	Monday, March 09, 2026

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -Support east end of deck beam to house per code with hanger or have engineer address |
| | | -Provide sewer tracer wire port at grade |

Comments: