

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251179  
Address: 15 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Wednesday, March 11, 2026

Corrective Action Required:

1 THIRD FLOOR Complete

Corrective Action Required:

2 SECOND FLOOR -Pre rock screw pattern and tape ok  
RC approved  
\*\*Screw pattern approved except as noted:  
Patch broken rock at;  
207  
-Tape joints and fire caulk sprinkler penetrations at soffits

Corrective Action Required:

3 FIRST FLOOR -Pre rock screw pattern ok  
- RC approved Units only  
-1st layer at shear walls ok

**Comments:**