

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20243308  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Tyler Schreck	Partial	Thursday, March 12, 2026

Informational:

1	Misc	2-17-26 NS Site visited for bacteriological sampling associated with new water main installation. Two bacteriological samples were collected today at approximately 11AM to and transported to Blue Vally Labs at 2pm today. Water main pending acceptable bacteriological results prior to approval for service. 2-18-26 NS Back-T test came back, and both samples passed on the first round of test. results will be uploaded to permit. 3/12/26 Tyler S. First sample of Bac-T test on C line was taken at 12:40 pm on 3/11/26 and taken to Blue Valley Labs. Just one sample taken. Results should come back this morning.
---	------	---

Comments: