

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20253743
Address: 2033 SW RED BARN LN, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed - Stop Work	Thursday, March 12, 2026

Corrective Action Required

1	Miscellaneous Correction	12/19/25 Tyler S There is no erosion control in front of house along curb. Silt fence is also down along the east side of property. Failure to correct this can result in a 2 day stop work order. 3/3/26 Tyler S. Mud and rock has been tracked out into the road. Needs to be cleaned up ASAP. 3/4/26 Tyler S. More mud and rock has been tracked out into road and silt fence is still down. Road needs to be cleaned up asap and erosion control needs to be fixed and maintained. A two day stop work order will be issued if this matter is not corrected. Fail. 3/10/26 Tyler S. More rock has been tracked into the road on top of what was there already that still has not been cleaned up. All rock and mud MUST be cleaned up. And erosion control needs maintained, silt fence is down. You have 2 days to correct this issue and clean up the street or a STOP WORK order will be issued. More rain is coming so we need to be sure we are keeping things clean.
---	--------------------------	---

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

3/12/26 Tyler S. A STOP WORK order is now in effect. Rock in the road needs to be cleaned up ASAP. Also silt fence needs to be put back up.

Comments: