

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253930  
Address: 2225 SW HEARTLAND CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Tyler Schreck	Passed	Thursday, March 12, 2026

Corrective Action Required:

1	Misc	3/12/26 Tyler S. DW is formed and compacted with 4" of clean rock. Approve to pour.
---	------	---

**Comments:**