

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20241886  
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                    |
|---------------------------------|--------------|----------|--------------------------|
| <b>Above Ceiling Inspection</b> | Khanh Nguyen | Failed   | Thursday, March 12, 2026 |

Corrective Action Required:

1 Misc

Corrective Action Required:

2 FIRST FLOOR

OK:

-All units hard lid ceiling, except unit below

**\*\*Deficiencies:**

-Unit 120-uncover plumbing chase wall; complete plumbing

Corrective Action Required:

3 SECOND FLOOR

OK:

-Hard lid ceiling in units

Corrective Action Required:

4 THIRD FLOOR

OK:

-Hard lid ceiling in units

Corrective Action Required:

5 FOURTH FLOOR

OK:

-Hard lid ceiling in units

**Comments:**