

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253755  
Address: 1063 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, March 12, 2026

Corrective Action Required:  
2 Misc

- Provide (2) king studs at all windows with header over 8'
- Provide Boca plate main floor bathroom
- Provide Boca plate at top plate bedroom 2

**Comments:**