

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251973
Address: 2619 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Thursday, March 12, 2026

Corrective Action Required:

1	Misc	10/28/25 Tyler S. Construction entrances need to have rock installed. Mud is tracking out into the road. 3/12/26 Tyler S. Mud at entrance has been tracked out into the road that needs cleaned up and silt fence needs put back up.
---	------	---

Comments: